



Standard Contract
& Advice Documents



Service and Maintenance

Electrical Equipment Safety Checklist

Using this document

The highlighted areas indicate where you need to add your company details and then simply insert your logo in place of the ceda logo.

Customer details		Engineer	
Name		Name	
Address		Company	
		Tel	
Post code		Date	

Electrical Installation (Up to the appliance)			
Distribution board correctly labelled?	Yes/No	Test certificate available?	Yes/No

Equipment Item description >		
Rating (kw)		
Voltage 1 phase		
Voltage Ph 1 3 phase Ph 2 Ph 3		
Current rating (amps)		
Current drawn (amps)		
Main equipotential bonding conductors? (yes/no)		
Main equipotential bonding connections visually OK (yes/no)		
Earth Continuity (ohms)		
Insulation (M.ohm)		
Is local isolator accessible (yes/no)		
Isolator Functioning (yes/no)		
Cable damage (yes/no)		
Safety devices working (yes/no)		
Visual inspection of terminals (OK/no)		
RCD/RCBO Protection (yes/no) (see below)		

Protective device type / rating		
Condition (see below)		
Action required (yes/no)		

Action required

.....
.....
.....

...
RCD/RCBO Protection is recommended by the Foodservice Equipment Industry for all commando socket and hard wired items.

Condition (Engineers assessment intended for guidance on life expectancy)

5 = Excellent (5yrs or more) 4 = Good (3-5 years) 3 = Fair (2-3 years) 2 = Poor (1-2 years) 1 = Very poor (recommend replacement)