



Standard Contract  
& Advice Documents

#S15

Service and Management

## Gas Safety Inspection Form

**Using this document**

The highlighted areas indicate where you need to add your company details and then simply insert your logo in place of the ceda logo.

Updated August 2024

# GAS SAFETY INSPECTION (COMMERCIAL CATERING APPLIANCES)

To confirm the validity of the gas operative please contact Gas Safe Register on 0800 408 5500 or visit [www.gassaferegister.co.uk](http://www.gassaferegister.co.uk)

**Job address:**  
 Name: .....  
 Address: .....  
 Postcode: .....  
 Tel No: .....

**Received by (signature)** .....

**Registration No:** ..... **Ref:** **GSI** .....

**Operative Licence No:** ..... **Date:** .....

**Business Name:** .....

**Print name:** .....

**Position held:** .....

Appliance Type	Make	Model	Serial No	Operating Pressure (mbar)	Heat input (kW)	Maximum CO <sub>2</sub> reading above appliance (if applicable)	Manufacturers information available (Yes/No)	Gas Isolation valve (Yes/No)	Gas Hose and required restraint fitted correctly (Yes/No/NA)	Electrical isolator fitted and correctly fused (Yes/No/NA)	FSD fitted to all burners (Yes/No/NA)	Pipework gastight (Yes/No)	Safe to use (Yes/No)	Serviced this visit (Yes/No)
1														
2														
3														
4														
5														
6														
7														
8														

Details of work carried out	Details of work required

ECV for catering area	Y/N/NA
Location	
Accessible	
Suitable valve type	
Handle attached	
Direction of operation shown	
Emergency notice present	
Automatic isolation fitted	
If yes do appliances have full flame safeguard?	
If not, is there a manual reset facility?	
Is there a warning notice?	
Is the system fitted with automatic pressure proving?	

Pipework within the catering area	Y/N/NA
Correctly identified?	
Correctly supported?	
Sleeves extend through walls/floors by 25mm	
Purge points fitted	
Test points fitted	
Satisfactory visual inspection	

Ventilation/Exhaust System	Y/N/NA/INT
Is a canopy system installed?	
If yes, is canopy overhead correct?	
Type of filtration (eg mesh/baffles)	
Exhaust/ventilation interlock provided and working?	
Automatic means of CO detection provided?	
Automatic means of CO <sub>2</sub> detection provided?	
CO/CO <sub>2</sub> detection interlocked with gas supply?	

Ventilation/Exhaust System (continued)	
Max. CO <sub>2</sub> recorded at visit - See IGE/MUP/19 figs 3 & 4	
1 ..... ppm	
2 ..... ppm	
3 ..... ppm	
4 Average ..... ppm	

An air quality test has been undertaken and the results noted for the gas powered catering appliances but the advice of a qualified ventilation engineer is required to ensure that the ventilation extraction system is fully compliant with any relevant national regulations currently in force.

Gas Operatives Signature
I confirm that all of the above work described on this form has been satisfactorily completed in accordance with the current Gas Safety (Installation and Use) Regulations, standards and procedures
Gas operatives signature .....